

ISO 9001: 2015 Certified Laboratories

Omega Laboratories

Lonand Phaltan Road, Near Sardecha Odha, Opp Ketaki Dhaba, Lonand. Tal- Khandala, Dist. – Satara.

Pin- 415521. Ph. 8600891946, email- vetdayapath@gmail.com

Date: 31/05/2025

To,


M/s. Vishwajyot International School, Padegoan

Report of water testing

PARAMETERS	Results	Permissible Range (WHO)	Remark
TOTAL COUNT	158	50000 CFU's per 100 ml	Within limit
COLI FORM BACTERIAL COUNT	12	150 CFU's per ml	Within limit
pH	7.2	7.0 – 8.5	Within limit
HARDNESS	50	180 – 320 ppm	Within limit
TDS	85	Less than 1000 ppm	Within limit
NITRATES	08	5- 10 mg/l	Within limit
SILICATES	00	5- 10 mg/l	Within limit
ALKALINITY	60	200- 300 ppm	Within limit
CHLORIDE	19	200 – 250 mg/l	Within limit
Electric conductivity	0.9	Up to 1.0	Within limit

Water is safe for drinking

Handwritten signature



Samples examined by

Dr. D.S. Suryawanshi – MVSc Pathology (Mumbai) Reg. No. MSVC 5715